

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Masonite Architectural

201 N Franklin, Ste 300., Tampa, FL, United States

1401 East Fourth Street, Marshfield, WI, US; 980 Point Township Drive, P.O. Box 112, Northumberland, PA 17857, US; 506 Municipal Drive, Jefferson City, TN 37760, US;

430, Route 108, Quest Saint-Ephrem, Quebec G0M 1R0, Canada

For the following product(s):

See Addendum

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January, 2017) for the school classroom<sup>1</sup> parameter.

<sup>1</sup> Modeled Product Type: Door (3ft x 7ft)

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-04501

Valid from: September 1, 2018 to June 30, 2019



INDOOR ADVANTAGE GOLD  
BUILDING MATERIALS



ISO/IEC 17025  
Product Certification Body  
17025

A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA

**SCS**global  
SERVICES

## Certification Addendum

# Masonite Architectural

Certification: Registration # SCS-IAQ-04501 | Valid from: September 1, 2018 to June 30, 2019

### Addendum **Indoor Advantage™ Gold**

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 (effective January, 2017) for the school classroom<sup>1</sup> parameter.

<sup>1</sup> Modeled Product Type: Door (3ft x 7ft)

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

#### Products: **Doors:**

Standard and Environmental Doors with cores of the following type:

Acoustic, Agrifiber, Fire Resistant Composite, High Density Fiberboard (HDF), Hollow Core, Laminated Veneer Lumber (LVL), Lead, Particleboard (Standard and NAUF), Staved Lumber, Structural Composite Lumber (SCL), Type I Foam

Cores:

Duraflake, Response Engineered Core

Unfinished Door Surfaces:

Hardboard, MDO and Veneer